



# CERTIFICATE

<b>Dnr</b> NF-04-01 04:127 S 01	Certificate concerning Fire extinguishing system for logging and construction machines which are subject to the SBF 127 Rules for permanently mounted extinguishing systems and other fire protection equipment on logging and construction machines
<b>Company</b> Fogmaker International AB P.O. Box 3204 350 53 Växjö	
<b>Product</b> Extinguishing system	
<b>Denomination</b> Fogmaker Contract work with pneumatic detection	
<b>Associated documents / Technical reports</b> Drawing dated December 15th 2003 showing Fogmaker Contract work with pneumatic detection, Performed installations with pneumatic detection hose until the end of year 2003 (dated January 9th 2004), A description of the product, EMC Test Report from Semko NO 201152F dated September 12th 2002, Environmental test from SP denoted P304246, Full scale test performed October 15th 2001	
<b>Special conditions</b> Volume of extinguishant in this case 2,0 L per m <sup>3</sup>  In the case of factory and/or series mounting a special approval will be needed.  Modifications which affect the performance of the system and/or change of material and components must be reported to Normgruppen.	
<b>Date of issue</b>  February 23rd 2004	
<b>Signature</b>  Tommy Arvidsson  Barbro Ahlén Executive officer	

Svenska Brandförsvarsföreningen  
Norm  
115 87 Stockholm  
Tele:08 588 475 11