



GMFZ.EX16446
Self-contained Automatic Extinguisher Units

[Page Bottom](#)

Self-contained Automatic Extinguisher Units

[See General Information for Self-contained Automatic Extinguisher Units](#)

FOGMAKER INTERNATIONAL AB
 SANDVAGEN 4
 SE-352 45 VAXJO, SWEDEN

EX16446

Fire extinguisher units containing water-based agent in accordance with the applicable requirements of Standard UL 1384.

Model	Agent Capacity, lb or liters	Max Protection Area, ft ²	Max Hazard Length, ft (any side)	Min/Max Ceiling Height, ft	Rating	Date of Installation Manual (Date of Supplement)
4L, 7.5L	3.7, 7.38	18.8 (1.75 m ²)	4.33 (1.3 m)	1 ft (0.3 m) min/ 6.5 ft (2 m) max	A, B	2013-10-16

These units are intended for the following:

- A. Protection of Class A surface fires and B flammable liquid fires.
- B. Protection where a free-burning fire may be expected.
- C. Storage and use within the temperature range of -22 to 149°F (-30 to 65°C).
- D. Normal operating Pressure of 1450 psi (100 bar).
- E. Intended for horizontal or vertical installation.
- F. To be designed and installed in accordance with the manufacturer's installation manual p/n 8021-002 dated October 16, 2013.
- G. To be maintained in accordance with the manufacturer's service manual p/n 8020-002, dated October 16, 2013 and Fogmaker International Parts Catalog, Edition 3.4.

[Last Updated](#) on 2014-01-13

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".